

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES

Bureau of Land and Water Resources

P.O. Box 10631

Jackson, Mississippi 39209

WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Adams
 WELL NUMBER A CODED \$
2001
 DATE WELL COMPLETED
4-9-90

PERMIT NUMBER
 NAME OF DRILLING FIRM
RAYBORN DRILLING, INC.

NAME & MAILING ADDRESS OF LANDOWNER
Joe Davidson
Rt. 7 Box 285
Natchez Ms 39120
 WELL LOCATION: SEC 18 TOWNSHIP 9 RANGE 2 N S E W
 DISTANCE _____ MILES _____ of _____ DIRECTION _____ NEAREST TOWN Anna's Bottom
 OTHER LANDMARK
12 mi. north of Natchez
 WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Home

PUMP DATA
 PUMP TYPE (Circle One): Submersible Turbine, Jet, Flowing Well, Other (Describe) _____
 POWER TYPE (Circle One): Electric Tractor, Diesel, Gasoline, Butane, Other (Describe) _____
 Pump Capacity (GPM) 50 No. of Stages 13 Setting Depth 84 FT.
 PUMP TEST
 Well yielded 50 GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA
 Well Depth 300' Casing Diameter (In.) 4" Casing Length (Ft.) 280'
 Type of Casing Sch 40 PVC Hole Depth 300' Depth to Static Water Level 20'
 TYPE OF COMPLETION: (Circle One or More): Natural Development, Gravel Packed, Underreamed, Telescoped, Open Hole, Other (Describe) _____
 Top of Lap Pipe or Reduction in Casing _____ FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA
 TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____
 Name of Organization Running Log _____

SCREEN DATA
 Diameter - Inches 4" Length - Feet 20' Slot Size - Inches .010
 Screen Type Sch 40 Slotted PVC Depth to Bottom - Feet 300'

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

 Driller's Remarks _____

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Top Soil	0	2
Streaked sand	2	220
sand	220	280

FORMATIONS (Continued)
 FROM TO
RECEIVED
 AUG 06 1990
 Department of Natural Resources
 Bureau of Land & Water Resources
 IF MORE SPACE IS NEEDED, USE BACK