

COUNTY WELL LOCATED	
Adams	
WELL NUMBER	CODED
A 2004	
DATE WELL COMPLETED	
3-20-98	

PERMIT NUMBER
0-60
NAME OF DRILLING FIRM
Rayborn Drilling, Inc.

NAME & MAILING ADDRESS OF LANDOWNER			
Kenneth Steiner			
P.O. Box 361			
Natchez, MS 39121			
WELL LOCATION:	SEC	TOWNSHIP	RANGE
	35	9 N	2 E
DISTANCE	DIRECTION	NEAREST TOWN	
10 Miles	North	of Natchez	
OTHER LANDMARK			
WELL PURPOSE (Circle One) Home, Irrigation, Municipal, Industrial, Fish Pond, etc.			

PUMP DATA			
PUMP TYPE (Circle One):			
<u>Submersible</u>		Turbine,	Jet Flowing Well,
Other (Describe)			
POWER TYPE (Circle One):			
<u>Electric</u>		Tractor,	Diesel, Gasoline, Butane,
Other (Describe)			
Pump Capacity (GPM)	No. of Stages	Setting Depth	
10	12	105 FT.	
PUMP TEST			
Well yielded _____ GPM with			
a drawdown of _____ ft.			
after _____ hours of pumping			

WELL DATA		
Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
350	4	330
Type of Casing	Hole Depth	Depth to Static Water Level
PVC	350	65'
TYPE OF COMPLETION: (Circle One or More):		
<u>Natural Development</u>		Gravel Packed, Underreamed, Telescoped, Open Hole, Other
(Describe)		
WELL GROUTED TO A DEPTH OF 10 FEET		
Type Grout (circle one): Cement, Bentonite, or Mix		

LOG DATA	
TYPE OF LOG RUN (Circle One):	
<input type="radio"/> No Log Run, <input type="radio"/> Electric, <input type="radio"/> Gamma Ray, <input type="radio"/> Density, <input type="radio"/> Sonic, <input type="radio"/> Neutron, <input type="radio"/> Other (Describe)	
Name of Organization Running Log	

SCREEN DATA		
Diameter - Inches	Length - Feet	Slot Size - Inches
4	20	.010
Screen Type	Depth to Bottom - Feet	
PVC	350	

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Dripper's Remarks	
Top of Lap Pipe or Reduction in Casing	
FEET	IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Topsoil	0	2			
Chalk	2	65			
Sand	65	105			
Hard shale	105	310			
Sand	310	350			
			03-23-98A10:21	RCVD	
IF MORE SPACE IS NEEDED, USE BACK					