

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Adams

WELL NUMBER CODED
D2038

DATE WELL COMPLETED
6-14-95

PERMIT NUMBER
0-60

NAME OF DRILLING FIRM
Raybern Drilling

Natchez, ms

NAME & MAILING ADDRESS OF LANDOWNER
Ariner Drilling
PO Drawer 825
Columbia, ms

WELL LOCATION: SEC TOWNSHIP RANGE
30 7 N 2 E

DISTANCE DIRECTION NEAREST TOWN
3 Miles East of Natchez

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Rig Supply

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P

Pump Capacity (GPM) No. of Stages Setting Depth FT.

PUMP TEST

Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth 240'	Casing Diameter (In.) 4"	Casing Length (Ft.) 200
Type of Casing PVC	Hole Depth 240	Depth to Static Water Level 100

LOG DATA

TYPE OF LOG RUN (Circle One):
No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF _____ FEET
Type Grout (circle one): Cement, Bentonite, or Mix

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA

Diameter - Inches 4"	Length - Feet 40	Slot Size - Inches 2-.025 1-.014
Screen Type SCH 40 PVC	Depth to Bottom of Screen 240	

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
TOP SOIL	0	2
Chalk	2	123
Sand	123	230
Chalk	230	240

FORMATIONS (Continued)

FROM TO

RECEIVED

JUN 29 1995

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK