James K Williams
owner on permit

Bureau of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

WELL NUMBER	CODED	PERMIT NUMBER
Adams #2		GW-15496 453
N/1		NAME OF DRILLING FIRM: Morphis Brothers Inc.
DATE WELL COMPLETED: 5/10/00		Trout La.

NAME & MAILING ADDRESS OF LANDOWNER
Lake Mary Planting Co.
P.O. Box 368
Ferriday, La. 71334

WELL LOCATION: SEC 8 TOWNSHIP 3 (N) S RANGE 4 E (W)

DISTANCE 7 Miles DIRECTION N of NEAREST TOWN Ft Adams

OTHER LANDMARK: Lake Mary

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Irrigation

PUMP DATA

PUMP TYPE (Circle One): Submersible, (Turbine), Jet, Flowing Well, Other (Describe) _____

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P _____

Pump Capacity (GPM)	No. of Stages	Setting Depth
		FT.

PUMP TEST
Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
190	16	130
Type of Casing	**Hole Depth**	**Depth to Static Water Level**
PVC	190	22

TYPE OF COMPLETION: (Circle One or More): (Gravel Packed), Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) _____

Top of Lap Pipe or Reduction in Casing
FEET — IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
16	60	.032
Screen Type		**Depth to Bottom - Feet**
PVC		

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Brown Clay	0	20			
Fine-Med Gray Sand	20	100			
Med Gray Sand	100	120			
Med & Coarse Gray Sand w/small gravel	120	190			

RECEIVED
MAY 22 2000
Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK