

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
AMITE
WELL NUMBER **2066** CODED
DATE WELL COMPLETED
12-3-97

PERMIT NUMBER
0-287
NAME OF DRILLING FIRM
Reeves Well Ser.

NAME & MAILING ADDRESS OF LANDOWNER
Robert C. Crubshaw
WELL LOCATION: SEC **13** TOWNSHIP **4 S** RANGE **4 W**
DISTANCE **8** Miles DIRECTION **N** of NEAREST TOWN **LIBERTY**
OTHER LANDMARK
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Checker House

PUMP DATA
PUMP TYPE (Circle One):
 Submersible Turbine Jet Flowing Well
Other (Describe)
POWER TYPE (Circle One):
 Electric Tractor Diesel Gasoline Butane
Other (Describe) H/P **1**
Pump Capacity (GPM) No. of Stages Setting Depth
19 **14** **120** FT.
PUMP TEST
Well yielded **60** GPM with
a drawdown of **0** ft.
after **1** hours of pumping

WELL DATA
Well Depth **150'** Casing Diameter (in.) **4"** Casing Length (Ft.) **20'**
Type of Casing **PVC** Hole Depth **150'** Depth to Static Water Level **90'**
TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other
(Describe) **10 gal sand**
WELL GROUTED TO A DEPTH OF **10** FEET
Type Grout (circle one): Cement Bentonite, or Mix

LOG DATA
TYPE OF LOG RUN (Circle One):
No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe)
Name of Organization Running Log

SCREEN DATA
Diameter - Inches **4"** Length - Feet **10'** Slot Size - Inches **10 Thd's.**
Screen Type **PVC** Depth to Bottom - Feet **150'**

GEOLOGIC DATA (Office Use Only)
Surface Elev. Geologic Unit Unit Thickness Depth to Top
Subs. SWL Date Analysis Aquifer Test
Driller's Remarks
Top of Lap Pipe or Reduction in Casing
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
clay	0	20			
sand & gravel	20	70			
chalky sand	70	120			
coarse sand	120	150			

05-23-98A99:37 RVD

IF MORE SPACE IS NEEDED, USE BACK