

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Bureau of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Amite

WELL NUMBER CODED PERMIT NUMBER
E 2052

DATE WELL COMPLETED
7-10-91

NAME OF DRILLING FIRM
FITZGERALD Well Serv

NAME & MAILING ADDRESS OF LANDOWNER
Bill Liebert
RR - Summit Ms.

WELL LOCATION: SEC TOWNSHIP RANGE
12 4 N 6 E W

DISTANCE DIRECTION NEAREST TOWN
Miles *W* of *Summit*

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Home

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P

Pump Capacity (GPM) No. of Stages Setting Depth
10 *8* *90* FT.

PUMP TEST
Well yielded *25* GPM with
a drawdown of *2* ft.
after *1* hours of pumping

WELL DATA

Well Depth <i>112</i>	Casing Diameter (In.) <i>4</i>	Casing Length (Ft.) <i>102</i>
Type of Casing <i>PVC</i>	Hole Depth <i>112</i>	Depth to Static Water Level <i>64</i>

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
(Describe)

Top of Lap Pipe or Reduction in Casing
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One):
 No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches <i>4</i>	Length - Feet <i>10</i>	Slot Size - Inches <i>.014</i>
Screen Type <i>PVC</i>	Depth to Bottom - Feet <i>112</i>	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
<i>Red clay</i>	<i>0</i>	<i>20</i>	RECEIVED AUG 08 1991 Dept. of Environmental Quality Bureau of Land & Water Resources		
<i>Red Chalk</i>	<i>20</i>	<i>60</i>			
<i>Red Sand</i>	<i>60</i>	<i>95</i>			
<i>Common Sandstone</i>	<i>95</i>	<i>112</i>			

IF MORE SPACE IS NEEDED, USE BACK