

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED AMITL	
WELL NUMBER F 2020	CODED
DATE WELL COMPLETED 6-12-97	

PERMIT NUMBER 0-287
NAME OF DRILLING FIRM REEVES WELL SER.

NAME & MAILING ADDRESS OF LANDOWNER			
WELL LOCATION: SEC 4 TOWNSHIP 3 RANGE 2			
DISTANCE IN TOWN MILES of GLOSTER NEAREST TOWN			
OTHER LANDMARK			
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc. CONVINCE STORE			

PUMP DATA			
PUMP TYPE (Circle One): Submersible Turbine, Jet, Flowing Well, Other (Describe)			
POWER TYPE (Circle One): Electric Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P 34			
Pump Capacity (GPM) 14	No. of Stages 13	Setting Depth 95	FT.
PUMP TEST			
Well yielded 30 GPM with a drawdown of 0 ft. after 72 hours of pumping			

WELL DATA		
Well Depth 100	Casing Diameter (In.) 4"	Casing Length (Ft.) 20'
Type of Casing PVC	Hole Depth 100	Depth to Static Water Level 70'
TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) 10 GAL COARSE SAND		
WELL GROUTED TO A DEPTH OF 10 FEET Type Grout (circle one): Cement Bentonite, or Mix		

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) No Log Run	
Name of Organization Running Log	

SCREEN DATA		
Diameter - Inches 4"	Length - Feet 10'	Slot Size - Inches 10 THDS.
Screen Type PVC	Depth to Bottom - Feet 100'	

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test
Driller's Remarks			
Top of Lap Pipe or Reduction in Casing			
FEET		IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
CLAY	0	5	RECEIVED SEP 23 1997 Dept. of Environmental Quality Office of Land & Water Resources		
SAND & GRAVEL	5	50			
LOBBY SAND	50	60			
SAND & PEN GRAVEL	60	100			

IF MORE SPACE IS NEEDED, USE BACK