

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED AMITE	PERMIT NUMBER 0-287
WELL NUMBER F-2021	NAME OF DRILLING FIRM REEVES WELL SER.
DATE WELL COMPLETED 6-1-97	

NAME & MAILING ADDRESS OF LANDOWNER
JAMES R. FORMAN
HWY 33 WEST
GLOSTER MISS

WELL LOCATION: SEC **27** TOWNSHIP **3** RANGE **2**
S W

DISTANCE **2** Miles DIRECTION **S.E.** of NEAREST TOWN **GLOSTER**

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
HOME

PUMP DATA

PUMP TYPE (Circle One): **Submersible** Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One): **Electric** Tractor, Diesel, Gasoline, Butane, Other (Describe) **H/P**

Pump Capacity (GPM) **19** No. of Stages **12** Setting Depth **120** FT.

PUMP TEST
Well yielded **60** GPM with a drawdown of **0** ft. after **4** hours of pumping

WELL DATA

Well Depth 160	Casing Diameter (In.) 4"	Casing Length (Ft.) 20'
Type of Casing PVC	Hole Depth 160	Depth to Static Water Level 90

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other
10 GAL. SAND

WELL GROUTED TO A DEPTH OF **10** FEET
Type Grout (circle one): **Cement**, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 4"	Length - Feet 10	Slot Size - Inches 10 THDS.
Screen Type PVC	Depth to Bottom - Feet 160	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
CLAY	0	10
SAND	10	60
CHALK	60	150
SAND	150	160

FORMATIONS (Continued)

RECEIVED

SEP 23 1997

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK