

AMITE

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED	
WELL NUMBER	CODED
1-2023	
DATE WELL COMPLETED	
8-15-97	

PERMIT NUMBER	0-60
NAME OF DRILLING FIRM	Raybold Drilling
	Natchez MS

NAME & MAILING ADDRESS OF LANDOWNER			
John Rommie			
4718 Bernich Cassels Rd			
Gloster MS 39638			
WELL LOCATION	SEC	TOWNSHIP	RANGE
	14	3	S 2 E
DISTANCE	DIRECTION	NEAREST TOWN	
4 Miles	NE	of GLOSTER	
OTHER LANDMARK			
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.			

PUMP DATA		
PUMP TYPE (Circle One): Submersible Turbine Jet Flowing Well, Other (Describe)		
POWER TYPE (Circle One): Electric Tractor Diesel Gasoline Butane, Other (Describe) 2 H/P		
Pump Capacity (GPM)	No. of Stages	Setting Depth
		FT.
PUMP TEST		
Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping		

WELL DATA		
Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
169	4"	149
Type of Casing	Hole Depth	Depth to Static Water Level
PVC	169	115
TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)		

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)	
Name of Organization Running Log	

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA		
Diameter - Inches	Length - Feet	Slot Size - Inches
4"	20	.020
Screen Type	Depth to Bottom - Feet	
Sch 40 PVC	169	

Driller's Remarks	
Top of Lap Pipe or Reduction in Casing	
FEET	IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
TOP SOIL	0	2	RECEIVED SEP 24 1997 Dept. of Environmental Quality Office of Land & Water Resources		
CHALK	2	25			
SAND & GRASS	25	70			
CHALK	70	90			
SAND	90	169			
			IF MORE SPACE IS NEEDED, USE BACK		