

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED Amite		PERMIT NUMBER
WELL NUMBER 2038	CODES	NAME OF DRILLING FIRM Fitzgerald Water Well
DATE WELL COMPLETED 2-11-93		

NAME & MAILING ADDRESS OF LANDOWNER
Jeanett Tippin
R R Liberty, MS

WELL LOCATION: SEC **19** TOWNSHIP **3** RANGE **N 5 E**
DISTANCE **5** Miles DIRECTION **North** of NEAREST TOWN **Liberty**

OTHER LANDMARK

WELL PURPOSE: Home Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P **1/2**

Pump Capacity (GPM) **10** No. of Stages **8** Setting Depth **80** FT.

PUMP TEST
Well yielded **50** GPM with
a drawdown of **3** ft.
after **2** hours of pumping

WELL DATA

Well Depth 110'	Casing Diameter (In.) 4"	Casing Length (Ft.) 100'
Type of Casing PVC	Hole Depth 110'	Depth to Static Water Level 53'

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other
(Describe)

WELL GROUTED TO A DEPTH OF **0-10** FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA

Diameter - Inches 4"	Length - Feet 10'	Slot Size - Inches .014
Screen Type PVC sch 40	Depth to Bottom - Feet 110'	

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Red clay	0	20			
Red sand	20	40			
Red sand + gravel	40	80			
Red sand	80	100			
course sand + gravel	100	110			

RECEIVED

MAR 31 1993

Mississippi Department of Environmental Quality
Office of Land and Water Resources

IF MORE SPACE IS NEEDED, USE BACK