

AMITE
 (3) R 2021
 3-6-79

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

3-6 1979 Fitzgerald Well Serv Amite
 date well completed firm name county well located

| LANDOWNER: | description of formations encountered | from | to |
|---|---|------------------------------------|-------------------------------------|
| <u>Fanny Semonth</u> <u>R.R. Tibert, Jr.</u> (mailing address) | <u>Brack clay</u> <u>hard sand & gravel</u> <u>course sand & gravel</u> | <u>0</u> <u>20</u> <u>70</u> | <u>20</u> <u>70</u> <u>80</u> |
| <p>WELL LOCATION: <u>(1)</u> <u>(2)</u> sec. <u>20 T</u> <u>(3)</u> <u>(4)</u> <u>9</u> miles <u>E</u> of <u>Platy</u> (distance) (direction) (nearest town)</p> | | | |
| <p>WELL PURPOSE: (home, irrigation, municipal, industrial)</p> | | | |
| <p>WELL COMPLETION DATA:</p> | | | |
| (1) diameter (inches) <u>4</u> | | | |
| (2) total depth (feet) <u>80</u> | | | |
| (3) static water level (feet) <u>55</u> below above top of ground. | | | |
| (4) casing <u>PVC</u> <u>72</u> (material) (depth) | | | |
| <u>4</u> If telescope see back. (size) | | | |
| (5) screen <u>3</u> <u>72</u> (length) (depth to top) | | | |
| <u>4</u> <u>PVC</u> (size) (material) | | | |
| (6) pump <u>1/2</u> <u>10</u> (HP) (yield gpm) | | | |
| <u>Electric</u> (type power) | | | |
| (7) electric log <u>Yes</u> (yes or no) | | | |
| (organization running log) | | | |
| (8) how well bottom plugged <u>Land Shk</u> | | | |
| DRILLERS REMARKS: | | | |

Miss. Board of Water Comm.

MAR 28 1979

RECEIVED