

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 1063
Jackson, MS 39289-063
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Amite

WELL NUMBER
M-72

DATE WELL COMPLETED
5-19-04

PERMIT NUMBER

NAME OF DRILLING FIRM
Kitzwald Well Service

NAME & MAILING ADDRESS OF LANDOWNER
Roy Love
Enterprise Liberty, MS

Latitude:
Longitude:

WELL LOCATION. SEC 14 TOWNSHIP 2 N RANGE 3 E

DISTANCE 4 Miles DIRECTION West NEAREST TOWN of Liberty

OTHER LANDMARK

WELL PURPOSE Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
 Submersible Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P SA

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
<u>clay</u>	<u>0</u>	<u>20</u>
<u>Sandy gravel</u>	<u>20</u>	<u>60</u>
<u>red clay</u>	<u>60</u>	<u>80</u>
<u>white clay</u>	<u>80</u>	<u>100</u>
<u>Five sand</u>	<u>100</u>	<u>160</u>
<u>course sand</u>	<u>160</u>	<u>190</u>

WELL DATA

Well Depth <u>190'</u>	Casing Diameter (In.) <u>4"</u>	Casing Length (Ft.) <u>180'</u>
Type of Casing <u>PVC</u>	Hole Depth <u>190'</u>	Depth to Static Water Level <u>80'</u>

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA

Diameter - Inches <u>4"</u>	Length - Feet <u>10'</u>	Slot Size - Inches <u>10/10</u>
Screen Type <u>PVC</u>	Depth to Bottom - Feet <u>190'</u>	

RECEIVED

JUN 14 2004

BY: OLWR

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

I certify that the well was drilled, constructed and completed in accordance with all applicable Requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

Brad Kitzwald 029
Signature of Licensed Driller and License No.

5-19-04
Date

Additional Information Required On Back