

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Amite

WELL NUMBER CODED
2067

DATE WELL COMPLETED
APR 2-93

PERMIT NUMBER

NAME OF DRILLING FIRM
Fitzgerald Well Serv

NAME & MAILING ADDRESS OF LANDOWNER
Bonnie Miller
P.R. Liberty ms

WELL LOCATION: SEC *22* TOWNSHIP *2* RANGE *N 6 E W*

DISTANCE *7* Miles *W* of *Magnolia*

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Home

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) *H/P* *2*

Pump Capacity (GPM) *10* No. of Stages *8* Setting Depth *55* FT.

PUMP TEST
Well yielded *25* GPM with
a drawdown of *2* ft.
after *2* hours of pumping

WELL DATA

Well Depth <i>110</i>	Casing Diameter (In.) <i>4</i>	Casing Length (Ft.) <i>100</i>
Type of Casing <i>PVC</i>	Hole Depth <i>110</i>	Depth to Static Water Level <i>24</i>

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other

WELL GROUTED TO A DEPTH OF *10* FEET
Type Grout (circle one): Cement, Bentonite, Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) No Log Run

Name of Organization Running Log

SCREEN DATA

Diameter - Inches <i>4</i>	Length - Feet <i>10</i>	Slot Size - Inches <i>10/14</i>
Screen Type <i>PVC slotted</i>	Depth to Bottom - Feet <i>110</i>	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS ENCOUNTERED	FROM	TO
<i>Red clay</i>	<i>0</i>	<i>10</i>	REGISTERED	<i>25</i>	<i>110</i>
<i>FINE SAND</i>	<i>10</i>	<i>95</i>			
<i>COURSE SAND</i>	<i>95</i>	<i>110</i>			
			MAY 25 1993		
			Dept. of Environmental Quality Office of Land & Water Resources		
			IF MORE SPACE IS NEEDED, USE BACK		