

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Amite

WELL NUMBER *2069* CODED

DATE WELL COMPLETED
Sept 20-93

PERMIT NUMBER

NAME OF DRILLING FIRM
FITZGERALD WELL SERV

NAME & MAILING ADDRESS OF LANDOWNER
GLENN SCARDINA
RR. Liberty ms

WELL LOCATION: SEC *4* TOWNSHIP *2 N* RANGE *6 E*
W

DISTANCE *3* Miles DIRECTION *S* NEAREST TOWN *McKELINS*

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Home

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) *H/P 1/2*

Pump Capacity (GPM)	No. of Stages	Setting Depth
<i>10</i>	<i>8</i>	<i>65</i> FT.

PUMP TEST

Well yielded *40* GPM with a drawdown of *2* ft. after *2* hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
<i>75</i>	<i>4</i>	<i>65</i>
Type of Casing	Hole Depth	Depth to Static Water Level
<i>PVC</i>	<i>75</i>	<i>45</i>

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
<i>4</i>	<i>10</i>	<i>.014</i>
Screen Type	Depth to Bottom - Feet	
<i>PVC</i>	<i>75</i>	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
<i>Red Clay</i>	<i>0</i>	<i>15</i>	RECEIVED OCT 22 1993 Dept. of Environmental Quality Office of Land & Water Resources		
<i>Red Sand</i>	<i>15</i>	<i>59</i>			
<i>Coarse SAND & GRAVEL</i>	<i>59</i>	<i>75</i>			

IF MORE SPACE IS NEEDED. USE BACK