

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED <i>Amite</i>	WELL NUMBER <i>U 2055</i>	CODED	PERMIT NUMBER
DATE WELL COMPLETED <i>7-8-93</i>		NAME OF DRILLING FIRM <i>F. F. GERALD Well Service</i>	

NAME & MAILING ADDRESS OF LANDOWNER
CARL DemLER
RR - OSYKA MS

WELL LOCATION: SEC *35* TOWNSHIP *1* RANGE *N 6 E*
S 6 W

DISTANCE *7* Miles *W* of *OSYKA*

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Home

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) *H/P*

Pump Capacity (GPM) *10* No. of Stages *8* Setting Depth *75* FT.

PUMP TEST
Well yielded *20* GPM with a drawdown of *2* ft. after *2* hours of pumping

WELL DATA

Well Depth <i>110</i>	Casing Diameter (In.) <i>4</i>	Casing Length (Ft.) <i>100</i>
Type of Casing <i>PVC</i>	Hole Depth <i>110</i>	Depth to Static Water Level <i>41</i>

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF *10* FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One):
 No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches <i>4</i>	Length - Feet <i>10</i>	Slot Size - Inches <i>10/4</i>
Screen Type <i>PVC</i>	Depth to Bottom - Feet <i>110</i>	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS CONTINUED	FROM	TO
<i>Red Clay</i>	<i>0</i>	<i>20</i>			
<i>Red sand</i>	<i>20</i>	<i>85</i>			
<i>Coarse sandstone</i>	<i>85</i>	<i>110</i>			

RECEIVED

OCT 18 1993

Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK