

CODED TERN

Copy mailed to Board of Water Commissioners 8/5/69

Attala Co
M61 CODED
7-69
M.G.S.
7-18
date well completed

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

04218

1969 Rayne Central Co.
firm name

CODED
Attala
county well located

LANDOWNER:
City of Kosciusko
Kosciusko, Miss
(mailing address)

description of formations encountered	from	to
<u>Red. Sandy Clay</u>	<u>0</u>	<u>20</u>
<u>White. Sandy Clay & Clay Balls</u>	<u>20</u>	<u>45</u>
<u>Shales</u>	<u>45</u>	<u>80</u>
<u>Rock</u>	<u>80</u>	<u>81</u>
<u>Hard. Shale with Hard Stks</u>	<u>81</u>	<u>117</u>
<u>Shale</u>	<u>117</u>	<u>120</u>
<u>Rock</u>	<u>120</u>	<u>123</u>
<u>Sandy Shale with Hard Stks.</u>	<u>123</u>	<u>273</u>
<u>Rock</u>	<u>273</u>	<u>276</u>
<u>Shale, Strucks of Rock</u>	<u>276</u>	<u>311</u>
<u>Sandy Shale</u>	<u>311</u>	<u>327</u>
<u>Rock</u>	<u>327</u>	<u>332</u>
<u>Hard. Shale with Hard Stks</u>	<u>332</u>	<u>358</u>
<u>Hard. 87 ft</u>	<u>358</u>	<u>445</u>
<u>Shale, Strucks of Sand</u>	<u>445</u>	<u>453</u>

WELL LOCATION:
sec. 20 T. 14 N. R. 7 E.
New Water Works Plant
(distance) miles (direction) of (nearest town)

WELL PURPOSE: Municipal
(home, irrigation, municipal, industrial)

- WELL COMPLETION DATA:
- (1) diameter (inches) 18"
 - (2) total depth (feet) 445'
 - (3) static water level (feet) 145' below above top of ground.
 - (4) casing Steel, 376',
(material) (depth)
18" If telescope see back.
(size)
 - (5) screen 60', 376'
(length) (depth to top)
10", Stainless Steel
(size) (material)
 - (6) pump _____ (HP) _____ (yield gpm)
Electric
(type power)
 - (7) electric log yes
(yes or no)
Miss. Geo. Survey
(organization running log)
 - (8) how well bottom plugged Slurp

DRILLERS REMARKS:
Pump not installed
as of this date

AUG 6 1969

MISS. DIV. OF WATER CONTROL