MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES

Bureau of Land and Water Resources

P.O. Box 10631
Jackson, Mississippi 39209
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: Attala	
WELL NUMBER: M 2037	CODED:
DATE WELL COMPLETED: 8-27-86	
PERMIT NUMBER:	
NAME OF DRILLING FIRM: Harmon & Sons	

NAME & MAILING ADDRESS OF LANDOWNER
International Paper
Highway 12 East
Kosciusko, MS 39090

WELL LOCATION: Attala SEC 16 TOWNSHIP 14 (N) S RANGE 7 (E) W

DISTANCE 2 Miles DIRECTION E of NEAREST TOWN Kosciusko

OTHER LANDMARK: Rail Road Track

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Office use

PUMP DATA

PUMP TYPE (Circle One): 2-H.P. Airwell
Submersible, Turbine, (Jet), Flowing Well,
Other (Describe) ~~1-H.P. Goulds~~

POWER TYPE (Circle One):
~~Electric~~, Tractor, Diesel, Gasoline, Butane,
Other (Describe) 220

Pump Capacity (GPM)	No. of Stages	Setting Depth
15	0	180' FT.

PUMP TEST
Well yielded 15 GPM with
a drawdown of 7 ft.
after 1 hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
220	2"	205'

Type of Casing	Hole Depth	Depth to Static Water Level
PVC	220'	30

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other
(Describe) Sand Packed

Top of Lap Pipe or Reduction in Casing
FEET — IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One): ~~No Log Run~~
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe)

Name of Organization Running Log
—

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
2"	~~20'~~ 15'	.10

Screen Type	Depth to Bottom - Feet
PVC	220'

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Mixed Chalk	0	20
Grey Chalk & Sand	20	140
Hard Gray Chalk	140	180
Sand	180	220

FORMATIONS (Continued)	FROM	TO

RECEIVED
DEC 19 1986
Department of Natural Resources
Bureau of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK