

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Benton

WELL NUMBER E-20816 CODED

DATE WELL COMPLETED
2-15-02

PERMIT NUMBER
0-1610

NAME OF DRILLING FIRM
Larry Carpenter Well Co.

NAME & MAILING ADDRESS OF LANDOWNER
Laura Strickland
619 Betts Rd.
Ashland, ms.

Latitude:
Longitude:

WELL LOCATION. SEC 29 TOWNSHIP 2 RANGE N 11 W

DISTANCE 4 MILES DIRECTION NW NEAREST TOWN Ashland

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Home

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P 3/4

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Surface Soil	0	18
Med red Sand	18	45
Med white sand	45	80
White Clay	80	95
Med white sand	95	130
Coarse white sand	130	170

WELL DATA

Well Depth <u>170</u>	Casing Diameter (in.) <u>4</u>	Casing Length (ft.) <u>160</u>
Type of Casing <u>PVC</u>	Hole Depth <u>170</u>	Depth to Static Water Level <u>120</u>

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA

Diameter - Inches <u>4</u>	Length - Feet <u>10</u>	Slot Size - Inches <u>.013</u>
Screen Type <u>PVC</u>	Depth to Bottom - Feet <u>170</u>	

RECEIVED

JUN 28 2002

Dept. of Environmental Quality
Office of Land & Water Resources

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

I certify that the well was drilled, constructed and completed in accordance with all applicable Requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

Larry Carpenter 0-162
Signature of Licensed Driller and License No.

5-8-02
Date

Additional Information Required On Back