

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
 Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
Benton
 WELL NUMBER
H-2112
 CODED
 DATE WELL COMPLETED
8-28-01

PERMIT NUMBER
0-162
 NAME OF DRILLING FIRM
Larry Carpenter
Well Co.

NAME & MAILING ADDRESS OF LANDOWNER
Wendell Brown
2199 Lamar Ashland, MS.
 Latitude:
 Longitude:
 WELL LOCATION SEC TOWNSHIP RANGE
5 3 N 1 W
 DISTANCE DIRECTION NEAREST TOWN
3 Miles NW of Ashland
 OTHER LANDMARK
 WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Home

PUMP DATA

PUMP TYPE (Circle One):
 Submersible, Turbine, Jet, Flowing Well,
 Other (Describe) _____
 POWER TYPE (Circle One):
 Electric, Tractor, Diesel, Gasoline, Butane,
 Other (Describe) _____ H/P 1/4

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Surface Soil	0	25
Med Whitesand	25	60
White Clay	60	85
Fine white sand	85	115
Coarse white sand	115	150

RECEIVED
 JUN 28 2002
 Dept. of Environmental Quality
 Office of Land & Water Resources

Top of Lap Pipe or Reduction in Casing
 FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

WELL DATA

Well Depth <u>150</u>	Casing Diameter (In.) <u>4</u>	Casing Length (Ft.) <u>140</u>
Type of Casing <u>PVC</u>	Hole Depth <u>150</u>	Depth to Static Water Level <u>105</u>

TYPE OF COMPLETION: (Circle One or More):
 Gravel Packed, Underreamed, Telescoped,
 Natural Development, Open Hole, Other
 (Describe) _____

WELL GROUTED TO A DEPTH OF 10 FEET
 Type Grout (circle one): Cement, Bentonite, or Mix

SCREEN DATA

Diameter - Inches <u>4</u>	Length - Feet <u>10</u>	Slot Size - Inches <u>.013</u>
Screen Type <u>PVC</u>	Depth to Bottom - Feet <u>150</u>	

I certify that the well was drilled, constructed and completed in accordance with all applicable Requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

Larry Carpenter 0-162
 Signature of Licensed Driller and License No.

4-21-02
 Date

Additional Information Required On Back