

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Bureau of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED COCAIN BATTON	WELL NUMBER M 2018	PERMIT NUMBER
DATE WELL COMPLETED 6-24-92	NAME OF DRILLING FIRM Wilson Well Co. Inc.	
ADDRESS Whitowille, Tr. 3508		

NAME & MAILING ADDRESS OF LANDOWNER TERRELL FORD			
7245 BUTTERFLY			
Memphis, Tr. 38133			
WELL LOCATION: SEC	TOWNSHIP	RANGE	
9	T4	S R2 E	
DISTANCE	DIRECTION	NEAREST TOWN	
8 1/2	South	ASHLAND	
OTHER LANDMARK 1 mile from Baton Tippan Co. Line			
WELL PURPOSE (Home, Irrigation, Municipal, Industrial, Fish Pond, etc.)			

PUMP DATA		
PUMP TYPE (Circle One): Submersible Turbine, Jet, Flowing Well, Other (Describe)		
POWER TYPE (Circle One): Electric Tractor, Diesel, Gasoline, Butane, Other (Describe)		
Pump Capacity (GPM)	No. of Stages	Setting Depth
10	9	42 FT.
PUMP TEST		
Well yielded 10 GPM with a drawdown of _____ ft. after _____ hours of pumping		

WELL DATA		
Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
49	4'	39
Type of Casing	Hole Depth	Depth to Static Water Level
P.C.	49	8
TYPE OF COMPLETION: (Circle One or More): Gravel Packed , Underreamed, Telescoped, Natural Development, Open Hole, Other		
Top of Lap Pipe or Reduction in Casing		
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE		

LOG DATA	
TYPE OF LOG RUN (Circle One): No Log Run , Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)	
Name of Organization Running Log	

SCREEN DATA		
Diameter - Inches	Length - Feet	Slot Size - Inches
4'	10	.010
Screen Type	Depth to Bottom - Feet	
P.C.	49	

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test
Driller's Remarks			

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Brown CLAY	0	15			
White Sand	15	45			
Mixed Clay & Sand	45	47			
Rock	47	48			
Blue Clay	48	49			

RECEIVED

AUG 28 1992

Dept. of Environmental Quality
Bureau of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK