MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources
P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: BOLIVAR
WELL NUMBER: D2021 | CODED:
DATE WELL COMPLETED: 04/30/98

PERMIT NUMBER:
NAME OF DRILLING FIRM: LAYNE-CENTRAL, a division of Layne Christensen Company

NAME & MAILING ADDRESS OF LANDOWNER:
MING PLANTING COMPANY
ROUTE 1, BOX 466
SHELBY, MS 38774

WELL LOCATION: SEC 26 TOWNSHIP 24 N RANGE 6 W
DISTANCE 3 Miles DIRECTION WEST of NEAREST TOWN WINSTONVILLE
OTHER LANDMARK:
WELL PURPOSE: Home, (Irrigation), Municipal, Industrial, Fish Pond, etc.: IRRIGATION

PUMP DATA - PUMP BY OTHER CONTRACTOR

PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe)
POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P

Pump Capacity (GPM)	No. of Stages	Setting Depth
		FT.

PUMP TEST
Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
105'	16"	65'

Type of Casing	Hole Depth	Depth to Static Water Level
PVC	105'	

TYPE OF COMPLETION: (Circle One or More): (Gravel Packed), Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one) (Cement), Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): (No Log Run), Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)
Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing: FEET
IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
16"	40'	.050

Screen Type	Depth to Bottom - Feet
PVC	105'

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
CLAY	0	15
FINE SAND	15	35
BORDERLINE SAND	35	45
COARSE SAND, PEA GRAV.	45	105

FORMATIONS (Continued)	FROM	TO

05-26-98A09:26 RCVD

IF MORE SPACE IS NEEDED, USE BACK