GW 6033 OK for 5/03 GW-6033

BOLIVAR M 47

MISSISSIPPI BOARD OF WATER COMMISSIONERS

E 109 #12

C 1137

WATER WELL DRILLERS LOG

8-20-61

Date: August 20, 19 61, Driller: Layne-Central Company (Name) County Bolivar

City of ~~Baxter~~ Cleveland

(1) Owner of Land: ~~Baxter Laboratories,~~ Inc. (Name)

Cleveland, Mississippi (Address)

(2) Location: ____ ¼, ____ ¼, Sec. 9 T 22N R 5W,

1 miles (distance) north (direction), of Cleveland (Nearest Town),

(3) Topography: flat (Hilly) (Flat) (Level)

(4) Purpose of Well: industrial (Domestic Irrigation Municipal, Industrial, Other)

Information upon completion of well:

(1) Diameter 10X6 inches.

(2) Total Depth 796' -5" feet.

(3) Water Level 28' -3" feet below top of ground.

(4) Cased to 735' -7", Size 10",

(5) Screen: Size 6", Length 50'.
10' -10" Back pressure valve and lap.

(6) Were any formations sealed against pollution?

yes yes, ____ no.

If YES depth of formation

Why Sealed with cement grout; full length of casing.

Drillers Remarks:

RECEIVED SEP 6 1961 MISS. BOARD OF WATER COMM.

Description & Color of Materials Sand, Clay, Red Clay, Shell, etc.	Thickness Feet	Depth Feet
Brown clay	12	12
Brown sand, fine	12	24
Sand	41	65
Coarse sand	33	98
Coarse sand & Pea gravel	18	116
Sand & gravel	6	122
Blue clay	18	140
Sand	32	172
Sand & strks. of shale	68	250
Sand	134	384
Sand, strks shale	51	435
Shale	45	480
Sand	17	497
Sandy shale	97	594
Sand	34	628
Shale	35	663
Sand	7	670
Shale	49	719
Sand, strks. shale	11	730
P.K. sand	66	796

(Use Back Side)

Well No.

Mail this copy to Board of Water Commissioners 429 Miss. St. Jackson, Miss.