
State Well Report



Part 1

Mississippi Department of Environmental Quality
Office of Land and Water Resources
P.O. Box 10631
Jackson, MS 39289-0631
(601)961-5210
(601)354-6938 (fax)

	For Office Use Only
Aquiter:	1
4	7-111
Well #:	
.S. Elevati	ion:
E-Log#: _	

State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.

Well Owner Information	37 Well Location Latitude: N 33° 22.921° 55 Longitude: W 90° 58.006°				
Owner Name PARKER & SON Mailing Address: 105 S FIFTH AVE	Method of Lat/Long (circle one): Conventional Survey, USGS quad, Hand-held GPS, Survey-grade GPS				
	USGS quad, rand-neid Grs, Survey-grade Grs				
	<u>SE</u> ¹ / ₄ <u>SW</u> ¹ / ₄ Sec <u>30</u> Twn <u>21N</u> Rng <u>7W</u>				
CLEVELAND MS 30732 City State Zip Code	Distance Direction Nearest Town 3 Miles NE of BENOIT				
Telephone No. ()					
Well Data					
Purpose of Well (circle one) Home Industrial Public Supply	frigation Fish Culture Other				
Date well drilling started: 7/22/05 Date well drilling completed: 7/22/05					
If flowing, method of flow regulation: Valve Other (describe)					
Static Water Level: feet above or (circle one) land surface Date measured:					
Method of Measurement (circle one) seel tape electric tape air line other:					
Hole depth: 120 Well depth: 120 Well grouted to a depth of 10 feet					
Type of grout (circle one): Cement Hentonite Mix					
Casing Length: 80 feet Casing diameter: 10 inches Type of casing: PVC					
Screen Length: 40 feet Screen diameter: 10	inches Type of screen: PVC				
Screen slot size:					
Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development Other (describe):					
Top of lap pipe or reduction in casing: feet If telescoped or more than one screen, describe on back of page					
Logs run (circle all applicable): No log run Electric Gamma Ray Density Sonic Neutron Other:					
Name of organization running log(s):					
I certify that the well drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi					
Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.					
Sidney Cook #0-289	In Cour				
Print Name of Water Well Contractor and License No.	Signature of Water Well Contractor				

RECEIVED


AUG 2 2 2005

BY: OLWR

Ground Level

Description of Formations Encountered	From	To
Clay	0	35
Sand	35	56
Sand and Gravel	56	77
Heavy Sand & Gravel	77	120
	<u> </u>	
	ļ	
	<u> </u>	
	ļ	
	-	
	 	
	+	
	 	
	_	
	.L	لـــــا

If more than one screen, show location of each on sketch



RECEIVED

AUG 2 2 2005

BY: OLWR

STATE WELL REPORT

Part 2

Pump Installer's Completion Report
Mississippi Department of Environmental Quality
Office of Land and Water Resources P.O. Box 10631 Jackson, MS 39289-0631 (601)961-5210 (601)354-6938 (fax)

SIDNEY COOK

Date completed: 7/24/05

_

This report should be prepared by the pump installer in installation of pump.	detail and filed with Department within 30 days of the		
Well Owner Information Owner Name PARKER & SON Mailing Address: 105 S FIFTH AVE	Well Location Latitude: N 33' 32.921' Longitude: W 90' 58.006' Method of Lat/Long (circle one): Conventional Survey, USGS quad, Harld-held GPS, Survey-grade GPS		
CLEVELAND MS 38732 City State Zip Code Telephone No. ()	SE ¼ Sw ¼ Sec 30 Twn 21N Rng 7W Distance Direction Nearest Town 3 Miles NE of BENOIT		
Pump Type Circle one	Power Type Circle one		
Air Lift Jet Submersible	Diesel Engine Gasoline Engine Natural Gas		
Bucket Piston Turbine	electric Motor Hand Tractor PTO		
Centrifugal Rotary Flowing Well	Windmill Other (specify):		
Other (specify):	Horse Power Rating of Motor: 30 HP		
Date Pump Installed: 7/24/05	Setting Depth:feet		
Rated Pump Capacity: 1800 Gallons Per Minute	Number of Stages:1		
Pump Test Data	Method of Measuring Water Level Circle one		
Date Well Tested: Feet Below Land Surface Pumping Water Level (B): Feet Below Land Surface	Air Line Electric Measuring Line teel Tape Other (specify):		
Drawdown [(B)-(A)]:Feet Below Land Surface	For flowing well, measured shut in head:feet		
Test Pumping Rate:Gallons Per Minute	Well yieldedGPM with a drawdown of		
Duration of Pump Test (minimum 4 hours):hours	feet afterhours of pumping		
I HEREBY CERTIFY that the above statements are true to the best of my knowledge. Matt Stephens #0-743P Print Name of Pump Installer and License No. (if applicable) Signature of Pump Installer			

RECEIVED

AUG 2 2 2005

BY: OLWR