County: Bolivar			
Permit #: <u>GW419</u>	٤	70	
Driller AME 1	H	46	BEA
Date drilling completed:	4	-17-	07

State Well Report

Part 1

Mississippi Department of Environmental Quality
Office of Land and Water Resources
P.O. Box 10631
Jackson, MS 39289-0631
(601)961-5210
(601)354-6938 (fax)

For Office Use Only:	
Aquifer:	
Well #: 4-118	
L. S. Elevation:	
E-log #:	

State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well. Well Location Well Owner Information Latitude: 33. 40.30." Longitude: 90.55.17." Owner Name Dahomey Plantation Wine will End Method of Lat/Long (circle one): Conventional Survey, Mailing Address: Likeli and USGS quad, Hand-held GPS, Survey-grade GPS Direction Nearest Town
Miles NE of BENOTI Telephone No. Well Data Purpose of Well (circle one) Home Industrial Public Supply Irrigation Fish Culture Other: Date well drilling started: 4-17-07

Date well drilling completed: 4-17-07 If flowing, method of flow regulation: Valve _____ Other (describe) __ Static Water Level: 27 feet above or below (circle one) land surface Date measured: Method of Measurement (circle one) steel tape air line other: ___ Well grouted to a depth of _____feet Hole depth: _//5 Type of grout (circle one): Cement Bentonite Type of casing: PUC Casing diameter: / 6 inches Casing length: 75 Screen length: 40 feet Screen diameter: 16 inches Screen slot size: <u>.050</u> inches Setting depth: From Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development Other (describe): _ Top of lap pipe or reduction in casing: _____feet. If telescoped or more than one screen, describe on back of page Logs run (circle all applicable): (No log run Electric Gamma Ray Density Sonic Neutron Other: Name of organization running log(s): _ I certify that the well was drilled, constructed, and completed in accordance with all applicable requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws. Signature of Water Well Contractor Print Name of Water Well Contractor and License No.

RECEIVED

JUL 18 2007

BY: OLWE

Ground Level	
151 casing	
40 Sceen	
115'-	

Description of Formations Encountered	From	То
Clay	0	. 5
fine	5	50
medium	50	70
Coarse	70	111

If more than one screen, show location of each on sketch

Sketch the property layout and include the following: 1) the well location; 2) any permanent structures on the property that may aid in locating the well; 3) any roads, power lines, or other items that may aid in locating the property and the well;	
4) indicate direction.	
Longshot Red. Well	
Longshot Rd. Well	
[Airstrip	
<u> </u>	
7 × 3 ± 1	
\$ \\ \tag{\frac{3}{\pi}}	
Benoit	.*
Landowner Name: DAHOMEY PLANTATION	4

Signature of Water Well Syntractor

Permit #: 6W 419 Date completed: 4-17-07

DIALE WELL REPURI Part 2

Pump Installer's Completion Report

Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 10631 Jackson, MS 39289-0631 (601)961-5210

(601)354-6938 (fax)

For (Office Use Only:
Aquifer:	
Well #:	8-118
Elevation:	•

installation of pump.	il and filed with the Department within 30 days of the
Well Owner Information	Well Location
Owner Name A HOME y CANTATION	Latitude 3-40-30 Longitude 90-51-17
Mailing Address C/O Jimus 1 125 00 M	Loughdae.
Mailing Address C/O Jimmy Wins Miller	
14 Hickory CREEK Cinec	
LiTTLE ROCK, AR. 72212	SW SW 1/4 Sec 7 TW2/N Rng 7W
City State Zip Code	Distance Direction Nearest Town
Telephone No. 501 692 - 4391	4 Miles NE of Beroit
Pump Type	
Circle one	Power Type Circle one
Air Lift Jet Submersible	Diesel Engine Gasoline Engine Natural Gas
Bucket Piston Turbine	Electric Motor Hand Tractor PTO
Centrifugal Rotary Flowing Well	Windmill Other (specify):
Other (specify):	Horse Power Rating of Motor:
Date Pump Installed 4 - 24 - 0 7	Setting Depth: 600 feet
Rated Pump Capacity 3000 Gallons Per Minute	Number of Stages:
Pump Test Data	Method of Measuring Water Level
Date Well Tested:	Circle one
Static Water Level (A):Feet Below Land Surface	Air Line Electric Measuring Line Steel Tape
Pumping Water Level (B):Feet Below Land Surface	Other (specify):
Drawdown [(B) - (A)]:Feet Below Land Surface	For flowing well, measured shut in head:feet
Test Pumping Rate:Gallons Per Minute	Well yieldedGPM with a drawdown of
Duration of Pump Test (minimum 4 hours):hours	feet afterhours of pumping
I HERERY CEPTIEV	
I HEREBY CERTIFY that the above statements are true to the best	of my knowledge.
Print Name of Pump Installer and Linear No. (16 - 17)	Ithe one
Print Name of Pump Installer and License No. (if applicable)	Signature of Purms Installed

RECEIVED

JUL 16 2007 BY: OLWR