

**MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL
QUALITY**

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED Bolivar	
WELL NUMBER R 2045	CODED
DATE WELL COMPLETED 26 July 98	

PERMIT NUMBER
NAME OF DRILLING FIRM Lambert Drilling

NAME & MAILING ADDRESS OF LANDOWNER Rufus Robinson Lamont ms			
WELL LOCATION:	SEC 31	TOWNSHIP 20 S	RANGE 9 E
DISTANCE 10 Miles	DIRECTION N	NEAREST TOWN Greenwood	
OTHER LANDMARK			
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc. home			

PUMP DATA		
PUMP TYPE (Circle One): <u>Submersible</u> , Turbine, Jet, Flowing Well, Other (Describe)		
POWER TYPE (Circle One): <u>Electric</u> , Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P		
Pump Capacity (GPM) 20	No. of Stages 8	Setting Depth 105 FT.
PUMP TEST Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping		

WELL DATA		
Well Depth 480	Casing Diameter (In.) 4 1/2	Casing Length (Ft.) 460
Type of Casing PVC	Hole Depth 480	Depth to Static Water Level 56
TYPE OF COMPLETION: (Circle One or More): <u>Natural Development</u> , Gravel Packed, Underreamed, Telescoped, Open Hole, Other (Describe)		

LOG DATA	
TYPE OF LOG RUN (Circle One): <u>Electric</u> , No Log Run, Gamma Ray, Density, Sonic, Neutron, Other (Describe)	
Name of Organization Running Log	

WELL GROUTED TO A DEPTH OF _____ FEET Type Grout (circle one): Cement, Bentonite, or Mix

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

SCREEN DATA		
Diameter - Inches 2"	Length - Feet 20	Slot Size - Inches 10
Screen Type PVC 1/66id	Depth to Bottom - Feet 460-480	

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
<div style="border: 2px solid black; padding: 10px; width: fit-content; margin: auto;"> <p align="center">RECEIVED</p> <p align="center">SEP 09 1998</p> <p align="center">Dept of Environmental Quality Office of Land & Water Resources</p> </div>					
IF MORE SPACE IS NEEDED, USE BACK					