

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES
Bureau of Land and Water Resources

P.O. Box 10631
Jackson, Mississippi 39209
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED CALHOUN	
WELL NUMBER H 205	CODED
DATE WELL COMPLETED SEPT 1989	

PERMIT NUMBER
NAME OF DRILLING FIRM ZEEPER Drilling
Pontotoc Ms

NAME & MAILING ADDRESS OF LANDOWNER Hubert Hamilton			
Rt 1			
Deerms Ms -			
WELL LOCATION: SEC	TOWNSHIP	RANGE	
30	13	N 10	E
DISTANCE	DIRECTION	NEAREST TOWN	
5 Miles	NE	Deerms	
OTHER LANDMARK			
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc. Home			

PUMP DATA		
PUMP TYPE (Circle One): Submersible , Turbine, Jet, Flowing Well, Other (Describe)		
POWER TYPE (Circle One): Electric , Tractor, Diesel, Gasoline, Butane, Other (Describe)		
Pump Capacity (GPM) 10	No. of Stages 10	Setting Depth 75 FT.
PUMP TEST		
Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping		

WELL DATA		
Well Depth 75'	Casing Diameter (In.) 4"	Casing Length (Ft.) 65'
Type of Casing PVC	Hole Depth 75'	Depth to Static Water Level 60'
TYPE OF COMPLETION: (Circle One or More): Gravel Packed , Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)		
Top of Lap Pipe or Reduction in Casing		
FEET	IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE	

LOG DATA	
TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)	
Name of Organization Running Log	

SCREEN DATA		
Diameter - Inches 4"	Length - Feet 10'	Slot Size - Inches .013 slot
Screen Type Slotted PVC	Depth to Bottom - Feet 75'	

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test
Driller's Remarks Very low yield out of this top sand - 2-3 GPM -			

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	REMARKS
TOP CLAY	0	20	<div style="font-size: 2em; font-weight: bold; opacity: 0.5;">RECEIVED</div> SEP 20 1989 Department of Natural Resources Bureau of Land & Water Resources
FINE BROWN SAND	20	60	
FINE GRAY SAND	60	75	
IF MORE SPACE IS NEEDED, USE BACK			