CARROLL
A43
7-15-74

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

BUTANE GAS CO. OF GREENWOOD

7-15-74 19 — date well completed
firm name
CARROLL — county well located

LANDOWNER: Gilbert Campbell

CARROLLTON (mailing address)

WELL LOCATION:
sec. 25 T. 20 N (S) R. 2 E (W)
6½ (distance) miles NW (direction) of CARROLLTON (nearest town)

WELL PURPOSE: Home (home, irrigation, municipal, industrial)

WELL COMPLETION DATA:
(1) diameter (inches) 4 x 2
(2) total depth (feet) 333
(3) static water level (feet) 170 below ~~above~~ top of ground.
(4) casing Steel (material), 313 (depth), 4 x 2 (size) If telescope see back.
(5) screen 10 (length), 313 (depth to top), 2" (size), Stainless (material)
(6) pump ½ (HP) K (yield gpm) Elec. (type power)
(7) electric log No (yes or no)
(organization running log)
(8) how well bottom plugged Back Pressure Valve

DRILLERS REMARKS:

description of formations encountered	from	to
Clay	0	35
Sand	35	98
Gravel	98	105
Sand	105	133
Rock	133	134
Sand	134	198
Clay	198	252
Shale & Rock	252	271
Sand & Shale	271	292
Rock	292	293
Sand & Shale	293	320
Sand	320	336
Shale	336	345

CODED

RECEIVED
AUG - 8 1974
MISS. BD. OF WATER COMM.