

CARROLL
B34
2-74

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

Feb 19 74 *Mark Martin Well Service Carroll*
date well completed firm name county well located

| LANDOWNER: | description of formations encountered | from | to |
|---|---------------------------------------|-------------|-------------|
| <i>John Carpenter Carrollton Rt (mailing address)</i> | | | |
| | <i>Sand</i> | <i>15'</i> | <i>28'</i> |
| WELL LOCATION: | <i>pipe & little sand</i> | <i>28'</i> | <i>100'</i> |
| sec. <i>3</i> T. <i>20</i> R. <i>3</i> | <i>Sand - gravel</i> | <i>100'</i> | <i>115'</i> |
| <i>9</i> miles <i>NW</i> of <i>Carrollton</i> | <i>pipe clay</i> | <i>115'</i> | <i>180'</i> |
| (distance) (direction) (nearest town) | <i>Mud</i> | <i>180'</i> | <i>247'</i> |
| WELL PURPOSE: <i>home</i> | <i>Sand</i> | <i>247'</i> | <i>300'</i> |
| (home, irrigation, municipal, industrial) | <i>ROCK layers</i> | <i>247'</i> | <i>260'</i> |
| WELL COMPLETION DATA: | | | |
| (1) diameter (inches) <i>4</i> | | | |
| (2) total depth (feet) <i>297</i> | | | |
| (3) static water level (feet) <i>176</i> below top of ground. | | | |
| (4) casing <i>plastic</i> (material) (depth) | | | |
| (size) If telescope see back. | | | |
| (5) screen <i>20</i> (length) <i>277</i> (depth to top) | | | |
| <i>4</i> (size) <i>plastic</i> (material) | | | |
| (6) pump <i>3/4</i> (HP) <i>7</i> (yield gpm) | | | |
| <i>Electric</i> (type power) | | | |
| (7) electric log (yes or no) | | | |
| (organization running log) | | | |
| (8) how well bottom plugged <i>cap</i> | | | |
| DRILLERS REMARKS: | | | |

MAR 13 1974

MISS. BD. OF WATER COMM