

CARROLL
B36
6/74

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

June 1974 Jack Martin Well serv. CARROLL
date well completed firm name county well located

| LANDOWNER: | description of formations encountered | from | to |
|---|---------------------------------------|------|-----|
| ARTHUR Mims Rt. CARROLLton, miss | Clay | 0 | 25 |
| (mailing address) | Sand | 25 | 50 |
| WELL LOCATION: sec 33 T 20 N R 3 E 5 miles NW of CARROLLton (distance) (direction) (nearest town) | Sand + GRAVEL | 50 | 85 |
| WELL PURPOSE: Home (home, irrigation, municipal, industrial) | Sand | 85 | 180 |
| WELL COMPLETION DATA: (1) diameter (inches) 4" (2) total depth (feet) 442' (3) static water level (feet) 105 below top of ground. (4) casing Plastic 422' (material) (depth) 4" (size) If telescope see back. (5) screen 20' 422' (length) (depth to top) 4" Plastic (size) (material) (6) pump 3/4 7 (HP) (yield gpm) Elec (type power) (7) electric log no (yes or no) (organization running log) (8) how well bottom plugged CAP | mud | 180 | 217 |
| | Mud with Rocks | 217 | 242 |
| | Green Sand | 242 | 292 |
| | CODED mud + Sand | 242 | 384 |
| | Sand | 384 | 392 |
| | Mud | 392 | 417 |
| | Sand | 417 | 442 |
| DRILLERS REMARKS: | | | |

RECEIVED
MAY 25 1974

MISS. BD. OF WA