MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES

Bureau of Land and Water Resources

P.O. Box 10631
Jackson, Mississippi 39209
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: Carroll	
WELL NUMBER: B 2011	CODED:
DATE WELL COMPLETED: 6-6-95	
PERMIT NUMBER:	
NAME OF DRILLING FIRM: Thomas Drilling	

NAME & MAILING ADDRESS OF LANDOWNER
Mary Wright
520 Milton Lane
Hoffman Estate, Ill. 60194

WELL LOCATION: GridB SEC 30 TOWNSHIP 21 (N) S RANGE 3 (E) W

DISTANCE 11 Miles DIRECTION NE of NEAREST TOWN Carrollton

OTHER LANDMARK: 4 miles NW of Sharkey Bayou

WELL PURPOSE: (Home) Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, (Jet), Flowing Well, Other (Describe) ____

POWER TYPE (Circle One): (Electric), Tractor, Diesel, Gasoline, Butane, Other (Describe) ____ H/P ____

Pump Capacity (GPM)	No. of Stages	Setting Depth
10	2	60 FT.

PUMP TEST

Well yielded 10 GPM with a drawdown of ____ ft. after ____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
125'	2"	120'
Type of Casing	**Hole Depth**	**Depth to Static Water Level**
PVC	125'	30'

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) Sand packed

Top of Lap Pipe or Reduction in Casing FEET

IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One): (No Log Run), Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) ____

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
2"	5'	.010
Screen Type	**Depth to Bottom - Feet**	
PVC WRAP	125'	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Dirt	0	3
Mixed clay	3	10
Sand & clay	10	25
~~Clay~~	~~25~~	~~125~~
Sand	25	125

FORMATIONS (Continued)	FROM	TO

RECEIVED
JUN 19 1995
Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK