

CARROLL
C 14
6-72

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

June 19 Jack Martin Carroll
date well completed firm name county well located

LANDOWNER:	description of formations encountered	from	to
John Crittenden Rt. Carrollton, Miss (mailing address)	Clay		22
	Pipe Clay + Sand		56
	Sand		125
WELL LOCATION:			
sec. 14 T. 20 S. R. 4 E			
7 miles NE of Carrollton (distance) (direction) (nearest town)			
WELL PURPOSE: home (home, irrigation, municipal, industrial)			
WELL COMPLETION DATA:			
(1) diameter (inches) 4"			
(2) total depth (feet) 125			
(3) static water level (feet) 77 below top of ground.			
(4) casing plastic, 115' (material) (depth)			
4" if telescope see back. (size)			
(5) screen 10' 115' (length) (depth to top)			
4" plastic (size) (material)			
(6) pump 3/4 10 (HP) (yield gpm)			
Elec (type power)			
(7) electric log (yes or no)			
(organization running log)			
(8) how well bottom plugged cap			
DRILLERS REMARKS:			

CODED

JUN 26 1972

MISS. BO. OF
WATER COMMISSIONERS