

Carroll  
 DLG  
 3-23-70

MISSISSIPPI  
 BOARD OF WATER COMMISSIONERS  
 416 North State Street  
 Jackson, Mississippi 39201

**CODED**

WATER WELL DRILLERS LOG

MARCH 23/70 19 BUTANE GAS CO. CARROLL  
 date well completed firm name county well located  
 GREENWOOD

LANDOWNER:	description of formations encountered	from	to
W.L. TAYLOR	SAND - GRAVEL	0	40
508 CYPRESS GREENWOOD (mailing address) MISS	CLAY	40	100
WELL LOCATION:	WHITE SAND	100	240
sec. 35 T. 19 N R. 2 E	FINE SAND	240	260
7 miles SW of CARROLLTON	SAND & SHALE	260	283
(distance) (direction) (nearest town)	WHITE SAND	283	290
WELL PURPOSE: HOME		290	304
(home, irrigation, municipal, industrial)			
WELL COMPLETION DATA:			
(1) diameter (inches) 4 3/4			
(2) total depth (feet) 304			
(3) static water level (feet) 150 below top of ground.			
(4) casing STEEL, 294, (material) (depth)			
(size) if telescope see back.			
(5) screen 10, 294 (length) (depth to top)			
2, STAINLESS STEEL (size) (material)			
(6) pump 3/4, 8 (HP) (yield gpm)			
ELEC (type power)			
(7) electric log NO (yes or no)			
(organization running log)			
(8) how well bottom plugged BACK PRESSURE VALVE			
DRILLERS REMARKS:			

**CODED**

MAR 27 1970

MISS. BD. OF  
 WATER COMM.