

CARROLL
D21
10/74

MISSISSIPPI BOARD OF WATER COMMISSIONERS

CODED

WATER WELL DRILLERS LOG

Date: Oct, 1974, Driller: Jack Martin County Carroll
(When well drilled) (Name) (Where well is located)

1) Owner of Land:	Description & Color of Materials Sand, Clay, Red Clay, Shell, etc.	Thick- ness Feet	Depth Feet
<u>John Emerich</u> <small>(Name)</small> <u>Greenwood Community Center</u> <small>(Address)</small>	Clay		25
2) Location: <u>NW 1/4, NE 1/4, Sec. 22 T19R2E</u> <u>7</u> miles <u>E</u> of <u>Greenwood</u> <small>(distance) (direction) (Nearest Town)</small>	Pipe clay + sand		38
3) Topography: <u>Hill</u> <small>(Hilly) (Flat) (Level)</small>	Sand + Gravel		68
4) Purpose of Well: <u>Domestic</u> <small>(Domestic Irrigation Municipal, Industrial, Other)</small>	Mud rock layers @ 70 and 86		115
Information upon completion of well:	Sand		160
(1) Diameter <u>4</u> inches. <u>320 ft + 4'</u> <small>balance</small>	Mud		251
(2) Total Depth <u>440</u> feet. <u>2"</u>	Sand		282
(3) Water Level <u>70</u> feet below top of ground.	Mud sandstone rock layers 28 ft to 295		295
(4) Cased to <u>410</u> , Size <u>4x2</u>	Sandy Muck		375
(5) Screen: Size <u>2</u> , Length <u>30</u>	Rock layers - mud		395
(6) Were any formations sealed against pollution? <input type="checkbox"/> yes, <input type="checkbox"/> no.	Sand		440
If YES depth of formation _____			
Why _____			
Drillers Remarks: _____			
Yield in gpm: <u>15</u>			
Size pump: <u>1 1/2 P</u>			
Type power: <u>Electric</u>			

RECEIVED
NOV - 1 1974

MISS. BD. OF WATER COMM

Mail this copy to Board of Water Commissioners 429 Miss. St. Jackson, Miss.