

Canoll  
D 2010

MISSISSIPPI  
BOARD OF WATER COMMISSIONERS  
416 North State Street  
Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

8/1/84 19  
date well completed

Life Well Supply  
firm name

Canoll  
county well located

| LANDOWNER: <u>Bell Bruner</u><br><u>Greenville</u><br><u>Miss</u><br>(mailing address)   | description of formations encountered | from | to  |
|--|---------------------------------------|------|-----|
|  |                                       |      |     |
| WELL LOCATION:<br>sec. <u>14 T 19 N</u> R. <u>2 E</u><br><u>6</u> miles <u>S</u> of <u>Greenville</u><br>(distance) (direction) (nearest town) | top soil clay                         | 0    | 20  |
|  | sand clay                             | 20   | 40  |
|  | sand                                  | 60   | 140 |
|  | clay                                  | 140  | 180 |
|  | sand                                  | 180  | 240 |
|  | clay                                  | 240  | 320 |
|  | sand                                  | 320  | 360 |
|  | clay                                  | 360  | 420 |
| WELL PURPOSE: <u>home</u><br>(home, irrigation, municipal, industrial)   | sand                                  | 420  | 460 |
| WELL COMPLETION DATA:  |                                       |      |     |
| (1) diameter (inches) <u>4 By 2</u>  |                                       |      |     |
| (2) total depth (feet) <u>460</u>  |                                       |      |     |
| (3) static water level (feet) <u>50</u> below above top of ground.   |                                       |      |     |
| (4) casing <u>PCC</u> , <u>360</u><br>(material) (depth)   |                                       |      |     |
| <u>4 1/2</u> if telescope see back.<br>(size)  |                                       |      |     |
| (5) screen <u>20</u> , <u>346</u><br>(length) (depth to top)   |                                       |      |     |
| <u>2</u> , <u>Stokes steel</u><br>(size) (material)  |                                       |      |     |
| (6) pump <u>3/4</u> , <u>160</u><br>(HP) (yield gpm)   |                                       |      |     |
| <u>elec</u><br>(type power)  |                                       |      |     |
| (7) electric log <u>(MS)</u><br>(yes or no)  |                                       |      |     |
| (organization running log)   |                                       |      |     |
| (8) how well bottom plugged <u>sted cap</u>  |                                       |      |     |
| DRILLERS REMARKS:  |                                       |      |     |

DEPT. OF NATURAL RESOURCES  
BUREAU OF LAND & WATER

FEB 21 1984

RECEIVED