

Carroll
E 13
10-30-68

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

10-30 1968 DYCER WELL & IRP Carroll
date well completed firm name county well located

| LANDOWNER: | description of formations encountered | from | to |
|---|---------------------------------------|------|-----|
| JAMES R. MALLON | | | |
| R. R. CARRELTON (mailing address) | SAND | 18 | 70 |
| WELL LOCATION: | SANDY SHALE ST. | 70 | 123 |
| sec. 14 T. 19 N R. 3 E | SAND | 123 | 164 |
| 2 miles E of CARRELTON | CLAY | 164 | 219 |
| (distance) (direction) (nearest town) | SHALE ROCK ST | 219 | 225 |
| WELL PURPOSE: DOMESTIC | GREEN SAND | 225 | 271 |
| (home, irrigation, municipal, industrial) | SAND | 271 | 293 |
| WELL COMPLETION DATA: | ROCK | 293 | 294 |
| (1) diameter (inches) 4" x 2" | SAND | 294 | 329 |
| (2) total depth (feet) 391' | GUMMY SHALE | 329 | 367 |
| (3) static water level (feet) 135' below top of ground. | SAND | 367 | 391 |
| (4) casing 2" GALV (material) 371' (depth) | CLAY | 391 | 410 |
| (size) If telescope see back. | | | |
| (5) screen 30' (length) 371' (depth to top) | | | |
| 2" STAINLESS STEEL (size) (material) | | | |
| (6) pump 1 (HP) 8 (yield gpm) | | | |
| 6250 (type power) | | | |
| (7) electric log No (yes or no) | | | |
| (organization running log) | | | |
| (8) how well bottom plugged BACIV 1/2 IN VALVE | | | |
| DRILLERS REMARKS: | | | |

CODED

DEC 2 1968

MISS. Bd. of Water Comm.