

Carroll
E 18
5-26-70

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

5-26-70 19 DYER WELL & IRRIGATION SERVICE CARROLL
 date well completed firm name county well located

LANDOWNER:	description of formations encountered	from	to
<u>H. E. Stanford</u>			
<u>Carrollton Miss.</u> (mailing address)	<u>Clay</u>	<u>0</u>	<u>18</u>
	<u>SAND</u>	<u>18</u>	<u>90</u>
	<u>SAND + CLAY</u>	<u>90</u>	<u>290</u>
WELL LOCATION: <u>190</u>	<u>SAND</u>	<u>240</u>	<u>310</u>
sec. <u>14</u> T. <u>19</u> N R. <u>3</u> E	<u>CLAY</u>	<u>310</u>	<u>315</u>
<u>1 1/2</u> miles <u>W</u> of <u>Carrollton</u>	<u>SAND</u>	<u>315</u>	<u>357</u>
(distance) (direction) (nearest town)			
WELL PURPOSE: <u>Home</u> (home, irrigation, municipal, industrial)			
WELL COMPLETION DATA:			
(1) diameter (inches) <u>4 x 2 1/2</u>			
(2) total depth (feet) <u>357</u>			
(3) static water level (feet) <u>46</u> below above top of ground.			
(4) casing <u>Steel</u> , <u>327</u> , (material) (depth)			
<u>4 x 2 1/2</u> if telescope see back. (size)			
(5) screen <u>30</u> , <u>327</u> (length) (depth to top)			
<u>2 1/2</u> , <u>Stainless Steel</u> (size) (material)			
(6) pump <u>2</u> , <u>30</u> (HP) (yield gpm)			
<u>Elec.</u> (type power)			
(7) electric log <u>NO</u> (yes or no)			
(organization running log)			
(8) how well bottom plugged <u>Back</u> <u>Pressure Valve</u>			
DRILLERS REMARKS:			

CODED

MAY 28 1970

MISS. BD. OF
 WATER COMMISSIONERS