

CARROLL

E 38

2-74

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201 CODED

WATER WELL DRILLERS LOG

Feb

1974

Jack Martin Well Serv.

Carroll

date well completed

firm name

county well located

LANDOWNER:	description of formations encountered	from	to
Billy Paves			
Carrollton RT 2 (mailing address)	Sand little gravel	16	72
WELL LOCATION:	Clay	72	120
sec. 20 T. 19 N. R. 3 E	Sand	120	200
5 miles SW of Carrollton (distance) (direction) (nearest town)			
WELL PURPOSE: Home (home, irrigation, municipal, industrial)			
WELL COMPLETION DATA:			
(1) diameter (inches) 4			
(2) total depth (feet) 260			
(3) static water level (feet) 103 below top of ground	CODED		
(4) casing Plastic (material) (depth)			
(size) if telescope see back.			
(5) screen 20 180 (length) (depth to top)			
4 Plastic (size) (material)			
(6) pump 1/2 7 (HP) (yield gpm)			
Electric (type power)			
(7) electric log No (yes or no)			
(organization running log)			
(8) how well bottom plugged CWP			
DRILLERS REMARKS:			

DECEMBER 15 1974
 MAR 13 1974

MISS. BD. OF WATER COMM.