GW-2768
Carroll
F 23
9-67

Codel

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

Sept 30 1967 Butane Gas of Greenwood Carroll
date well completed — firm name — county well located

LANDOWNER: Town of Carrollton
Carrollton Miss
(mailing address)

WELL LOCATION:
sec. 18 T 19 N R 4 E

1N (distance) miles (direction) of CARROLLTON (nearest town)

WELL PURPOSE: Municipal
(home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

(1) diameter (inches) 6"
(2) total depth (feet) 420'
(3) static water level (feet) 23 ~~below~~ above top of ground.
(4) casing STEEL (material), 390' (depth), 6" (size) If telescope see back.
(5) screen 30' (length), 390' (depth to top), 6" (size), STAINLESS STEEL (material)
(6) pump 15 (HP) 100 (yield gpm) ELECTRIC (type power)
(7) electric log No (yes or no)
(organization running log)
(8) how well bottom plugged BACK PRESSURE VALVE

DRILLERS REMARKS:

description of formations encountered	from	to
TOP CLAY	0	15
SAND	15	20
CLAY	20	30
SHALE	30	98
DARK GREY SAND	98	120
SHALE	120	150
GREEN SAND	150	170
SHALE	170	185
GREEN SAND	185	205
SHALE	205	380
VERY FINE SAND	380	389
MED TO COARSE SAND	389	420
SHALE	420	
TD 425'		
CASING SET 2' ABOVE GROUND & TOP 40' CEMENTED		

RECEIVED OCT - 5 1967 MISS. BOARD OF WATER COMM.