

CARROLL
F33
2-9-71

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

2-9-1971 date well completed
Smith well Drilling Co. firm name
Carroll county well located

LANDOWNER: Summit Homes
RFD
Carrollton miss
(mailing address)

WELL LOCATION:
sec. 30 T. 17 R. 4
about 2 miles S of Carrollton
(distance) (direction) (nearest town)

WELL PURPOSE: Home
(home, irrigation, municipal, industrial)

- WELL COMPLETION DATA:
- (1) diameter (inches) 9"
 - (2) total depth (feet) 362
 - (3) static water level (feet) 160 below top of ground.
 - (4) casing 2 1/2 galv. 2 9/4
(material) (depth)
 - 1/8 if telescope see back.
(size)
 - (5) screen 1/8
(length) (depth to top)
 - (size) (material)
 - (6) pump 3/4 red pump about 250
(HP) (yield gpm)
 - Electricity
(type power)
 - (7) electric log NO
(yes or no)
 - (organization running log)
 - (8) how well bottom plugged

description of formations encountered	from	to
red clay	0	22
red sand	22	50
white sand	50	61
rock	61	62
red clay	62	65
white clay		
sand mixture	65	140
gray sand	140	160
yellow clay		
green sand & sil.	160	210
blue clay	210	215
hard rock	215	217
black clay		
and a trace of sand	217	240
gray sand	240	260
yellow clay thin		
layers of rock	260	295
blue clay	295	318
gray sand clay		
impurities	318	325
blue sand	325	362

CODED

MAR 9 - 1971

DRILLERS REMARKS: This is a very good open well

MISS. BD. OF
WATER COM.