CARROLL
F59
8/79
Elbg #76

GW 02767

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

August 19 79 — date well completed
Herndon Well & Supply — firm name
Carroll — county well located

LANDOWNER: Town of Carrollton — Carrollton, MS
(mailing address)

WELL LOCATION:
sec. 18 T. 19 N ~~S~~ R. 4 E ~~W~~
Inside city limits
(distance) miles (direction) of (nearest town)

WELL PURPOSE: Municipal
(home, irrigation, municipal, industrial)

WELL COMPLETION DATA:
(1) diameter (inches) 10"
(2) total depth (feet) 849'
(3) static water level (feet) 20 below ~~above~~ top of ground.
(4) casing Steel (material), 809 (depth), 10" (size) if telescope see back.
(5) screen 42'3" (length), (depth to top) 4" (size), SS Ribbed (material)
(6) pump 25 (HP) 157 (yield gpm)
Elec (type power)
(7) electric log MS G S (yes or no)
M G S (organization running log)
(8) how well bottom plugged BW

DRILLERS REMARKS:

description of formations encountered	from	to
Brown Clay	0	6
Coarse tight Wht sand	6	20
Blue Clay	20	55
Rock	55	56
Blue Clay	56	70
Broken Streaks Clay and Sand	70	315
Blue Clay	315	345
Sandy Blue Clay	345	375
Sand	375	418
Blue Clay Sand Strks	418	485
Tight Gray Clay	485	524
Rock	524	525
Blue Clay Sand Strks	525	847
Rock	847	848
Sand	848	880
Blue Clay	880	930
Rock	930	931
Blue Clay	931	945

CODED

Miss. Board of Water Comm.
AUG 21 1979
RECEIVED