

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED
CARROLL

WELL NUMBER 2 CODED

F-70

DATE WELL COMPLETED
02/05/03

PERMIT NUMBER
GW 15789

NAME OF DRILLING FIRM
HERNDON WELL & SUPPLY

SHANNON, MS

15789
OK
pat
2/03

NAME & MAILING ADDRESS OF LANDOWNER
MCCARLEY WATER ASSOC ✓
P. O. BOX 666
MCCARLEY, MS 38646

Latitude: 333127N
Longitude: 895342W

WELL LOCATION: SEC 8 TOWNSHIP 19 RANGE 4
N E
W

DISTANCE DIRECTION NEAREST TOWN
INSIDE CITY LIMITS
Miles of

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
MUNICIPAL

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine, Jet, Flowing Well,
Other (Describe)

POWER TYPE (Circle One):
Electric, Tractor, Diesel, Gasoline, Butane,
Other (Describe) H/P 25

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
RED CLAY	0	18
WHITE SAND	18	25
BLACK SAND	25	218
BROWN SAND	218	278
GRAY CLAY & SAND	278	281
BROWN CLAY & SAND	281	310
GRAY CLAY & SAND	310	380
SAND & CLAY	380	500
SAND	500	630
CLAY & SAND	630	658

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
623'	12	522
Type of Casing	Hole Depth	Depth to Static Water Level
STEEL	658	72

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other
(Describe)

WELL GROUTED TO A DEPTH OF 522 FEET
Type Grout (circle one) Cement, Bentonite, or Mix

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
6	101	.030
Screen Type	Depth to Bottom - Feet	
SS RIBBED	623	

RECEIVED

FEB 11 2003

BY: OLWR

Top of Lap Pipe or Reduction in Casing
459 FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

I certify that the well was drilled, constructed and completed in accordance with all applicable Requirements of the Mississippi Department of Environmental Quality and/or the Mississippi Department of Health regulations and state laws.

Ricky Herndon
Signature of Licensed Driller and License No.

02/05/03
Date

Additional Information Required On Back