

CARROLL
G39
11/73
Log # 65

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

date well completed 19 73 firm name Jack Martin Well Service county well located Carroll

LANDOWNER:	description of formations encountered	from	to
<u>Dalton Alford</u>			
<u>Greenwood Rt 4</u> (mailing address)	<u>Sand</u>	<u>18</u>	<u>303</u>
WELL LOCATION:	<u>Gravel Sand 18-82</u>		
sec. <u>27</u> T. <u>18</u> N R. <u>2</u> E S # <u>6</u> W # <u>7</u>	<u>and 150-180</u>		
<u>6</u> miles <u>W</u> of <u>Carroll</u> (distance) (direction) (nearest town)	<u>Mud</u>	<u>303</u>	<u>385</u>
WELL PURPOSE: <u>Home</u> (home, irrigation, municipal, industrial)	<u>Brown Sand + Shell</u>	<u>385</u>	<u>435</u>
WELL COMPLETION DATA:	<u>Sand</u>	<u>435</u>	<u>495</u>
(1) diameter (inches) <u>4 1/2</u>	<u>2 1/2 rock</u>	<u>445</u>	<u>497</u>
(2) total depth (feet) <u>539</u>	<u>Mud</u>	<u>497</u>	<u>504</u>
(3) static water level (feet) <u>149</u> below top of ground.	<u>CODED</u>		
(4) casing <u>Steel</u> , <u>507</u> , (material) (depth)	<u>Sand</u>	<u>504</u>	<u>539</u>
(5) screen <u>30</u> , <u>507</u> (length) (depth to top)			
<u>2 1/2</u> , <u>Stainless Steel</u> (size) (material)			
(6) pump <u>1</u> , <u>15</u> (HP) (yield gpm)			
<u>3 phase</u> (type power)			
(7) electric log <u>Yes</u> (yes or no)			
<u>Miss Yes</u> (organization run)			
(8) how well bo			

DRILLERS REMARKS

NOV 18 1973

MISS. BD. OF
 WATER COMMISSIONERS