

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED	
Claiborne	
WELL NUMBER	CODED
M 2006	
DATE WELL COMPLETED	
2-27-98	

PERMIT NUMBER
0-60
NAME OF DRILLING FIRM
Raybern Drilling, Inc.
Address
Natchez, MS 39120

NAME & MAILING ADDRESS OF LANDOWNER			
Bud Wilson			
Rt. 1 Box 136-H			
Hermanville, MS 39086			
WELL LOCATION	SEC	TOWNSHIP	RANGE
	42	11	(N) 3 (E) W
DISTANCE	DIRECTION	NEAREST TOWN	
2 Miles	E	Port Gibson	
OTHER LANDMARK			
On Warrenton Rd.			
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.			
Home			

PUMP DATA		
PUMP TYPE (Circle One):		
Submersible	Turbine	Jet
Other (Describe)		
POWER TYPE (Circle One):		
Electric	Tractor	Diesel
Other (Describe)		
Pump Capacity (GPM)	No. of Stages	Setting Depth
20	18	170 FT.
PUMP TEST		
Well yielded _____ GPM with		
a drawdown of _____ ft.		
after _____ hours of pumping		

WELL DATA		
Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
360'	4"	340'
Type of Casing	Hole Depth	Depth to Static Water Level
PVC	360'	100'
TYPE OF COMPLETION: (Circle One or More):		
Gravel Packed	Underreamed	Telescoped
Natural Development	Open Hole	Other
(Describe)		
WELL GROUTED TO A DEPTH OF 10 FEET		
Type Grout (circle one): Cement, Bentonite, or Mix		

LOG DATA	
TYPE OF LOG RUN (Circle One):	
Electric	No Log Run
Gamma Ray	Density
Sonic	Neutron
Other (Describe)	
Name of Organization Running Log	

SCREEN DATA		
Diameter - Inches	Length - Feet	Slot Size - Inches
4"	20'	.010
Screen Type	Depth to Bottom - Feet	
Sch 40 PVC	360'	

GEOLOGIC DATA (Office Use Only)			
Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test
Driller's Remarks			
Top of Lap Pipe or Reduction in Casing			
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE			

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	
			FROM	TO
Top Soil	0	2		
Chalk	2	15		
Sand	15	70	03-03-98A10:08	RCVD
Hard Shale & Rock	70	335		
Sand	335	360		
IF MORE SPACE IS NEEDED, USE BACK				