

CLARKE

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES  
Bureau of Land and Water Resources

P.O. Box 10631  
Jackson, Mississippi 39209  
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED  
CLARKE

WELL NUMBER M 2018 CODED

DATE WELL COMPLETED  
10/31/88

PERMIT NUMBER  
D-205

NAME OF DRILLING FIRM  
CARR'S WELL SER.

BURKATUNNA, MS.

NAME & MAILING ADDRESS OF LANDOWNER  
PAUL EVANS  
RT. 2 BOX 126  
2 HUBBATA, MS.

WELL LOCATION: SEC 34 TOWNSHIP 2 RANGE N 15 E

DISTANCE 3 1/2 Miles DIRECTION SW of QUITMAN

OTHER LANDMARK

WELL PURPOSE  Irrigation,  Municipal,  Industrial,  Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):  
Submersible, Turbine, Jet Flowing Well,  
Other (Describe)

POWER TYPE (Circle One):  
Electric Tractor, Diesel, Gasoline, Butane,  
Other (Describe) H/P 1

Pump Capacity (GPM) 10 No. of Stages 2 Setting Depth 65 FT.

PUMP TEST

Well yielded 10 GPM with  
a drawdown of 3' ft.  
after 2 hours of pumping

WELL DATA

Well Depth 225 Casing Diameter (In.) 2" Casing Length (Ft.) 220

Type of Casing PVC Hole Depth 225 Depth to Static Water Level 50

TYPE OF COMPLETION: (Circle One or More):  
Gravel Packed, Underreamed, Telescoped,  
Natural Development Open Hole, Other

Top of Lap Pipe or Reduction in Casing  
FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One):  
No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron,  
Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches 2" Length - Feet 5' Slot Size - Inches 6

Screen Type PVC Depth to Bottom - Feet 225

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
TOP SOIL	0	1	MED. COARSE SD.	212	225
RED SAND	1	13			
" SD. & RD. CLAY	13	30			
WHITE SD. & CLAY	30	39			
GRAY CLAY	39	86			
ROCK STRATUM	86	149			
CLAY	149	176			
SD. & CLAY	176	192			
FINE SD.	192	197			
CLAY	197	207			
MED FINE SD	207	212			

IF MORE SPACE IS NEEDED, USE BACK