

CODED  
CODEL

CODEL CODED

CLARK  
P 17  
1-18-69

MISSISSIPPI  
BOARD OF WATER COMMISSIONERS  
416 North State Street  
Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

Clark  
Jones

1-18-69 date well completed  
Roy/Winst firm name  
Jones county well located

LANDOWNER	description of formations encountered	from	to
2500 First National Bank	Clay	0	25
Bldg Dallas Texas	Sandy Clay	25	50
(mailing address)	Sand	50	100
	Blue Clay	100	190
	Sand	190	325

Placid De Co  
2500 First National Bank  
Bldg Dallas Texas  
(mailing address)

WELL LOCATION:  
sec. 10 T. 1 N. R. 9 E.  
8 miles E. of Hildreth  
(distance) (direction) (nearest town)

WELL PURPOSE: office  
(home, irrigation, municipal, industrial)

- WELL COMPLETION DATA:
- (1) diameter (inches) 2
  - (2) total depth (feet) 325
  - (3) static water level (feet) 40 below top of ground.
  - (4) casing galv 315 (material) (depth)
  - (5) screen 10 315 (length) (depth to top)  
1/4" St Steel (size) (material)
  - (6) pump 1 12 (HP) (yield gpm)  
Rea (type power)
  - (7) electric log NO (yes or no)
  - (8) how well bottom plugged Washed

CODED

JAN 24 1969

MISS. BD. OF  
WATER COMMISSIONERS

DRILLERS REMARKS: