MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED	Clark
WELL NUMBER	Q 2026
CODED	
PERMIT NUMBER	
NAME OF DRILLING FIRM	Thompson Brothers Water Well Drlg.
DATE WELL COMPLETED	9/2/99

NAME & MAILING ADDRESS OF LANDOWNER: Swift Energy Co. 4616 Parkridge Rd. Benton La, 71006

WELL LOCATION	SEC	TOWNSHIP	RANGE
	15	1 N/S	8 E/W

DISTANCE	DIRECTION	NEAREST TOWN
2 Miles	E	of Goodwater

OTHER LANDMARK:

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.: Oilfield Production

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P 3/4

Pump Capacity (GPM)	No. of Stages	Setting Depth
5		100' FT.

PUMP TEST

Well yielded 20 GPM with a drawdown of 40 ft. after air lift hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
260	4	250
Type of Casing	**Hole Depth**	**Depth to Static Water Level**
PVC	260	55

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF 10 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks: Sand was very fine, no med. sand found

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
4	10	.06
Screen Type		**Depth to Bottom - Feet**
P.V.C. wrap		260

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Clay (Sumbo)	0	160
Shale	160	180
Fine sand & clay	180	240
Fine sand	240	260

FORMATIONS (Continued)	FROM	TO

RECEIVED
SEP 21 1999
Dept. of Environmental Quality
Office of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK.