

COAHOMA
BZO
3-5-10

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

ELOG. # 15

CODED

WATER WELL DRILLERS LOG

3-5 date well completed
20 Alexander Home Well & Supply Coahoma firm name
Coahoma County well located

LANDOWNER	description of formations encountered	from	to
Town of Friars Point	Brown Loam	0	10
Friars Point, Miss (mailing address)	Brown Clay	10	20
	Sand	20	90
	Gravel	90	120
	Sand	120	160
	Green Gumbo	160	330
	Sand	330	336
	Lime Rock	336	375
	Sand	375	500
	Gumbo	500	515
	Sand	515	600
	Gumbo	600	620
	Sand	620	716
	Gumbo	716	750
	Sand	750	795
	Gumbo	795	799
	Sand	799	817

CODED

NOV 12 1970

MISS. BD. OF
WATER COMM.

WELL LOCATION:
sec. 29 T. 23 N. R. 4 E
of Friars Point
(distance) miles (direction) (nearest town)

WELL PURPOSE: municipal
(home, irrigation, municipal, industrial)

- WELL COMPLETION DATA:
- (1) diameter (inches) 8" x 6"
 - (2) total depth (feet) 817'
 - (3) static water level (feet) 37' below top of ground.
 - (4) casing Steel 754' (material) (depth)
8" (size) If telescope see back.
 - (5) screen 61' (length) (depth to top)
6" Stainless Ribbed (size) (material)
 - (6) pump 30 406 (HP) (yield gpm)
Electric (type power)
 - (7) electric log yes (yes or no)
USGS (organization running log)
 - (8) how well bottom plugged B/w valve

DRILLERS REMARKS: