## Permit #: MS-GW-40409 Driller: Pete's Well Drilling Date drilling completed: 2/20/06

## **State Well Report**

Part 1

Mississippi Department of Environmental Quality
Office of Land and Water Resources
P.O. Box 10631
Jackson, MS 39289-0631
(601)961-5210
(601)354-6938 (fax)

For Office Use Only:	_
Aquifer:	
Well #: B-47	
L. S. Elevation:	
E-log #:	

State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.

30 days of completion of drilling of the well.	
Well Owner Information	Well Location
Owner Name Rodney Darrison	Latitude: 34 ° 20 ' 19 " Longitude: 90 ° 34 ' 3 Zu
Mailing Address: 5030 Moon Lake RD.	Method of Lat/Long (circle one): Conventional Survey,
	USGS quad, Hand-held GPS, Survey-grade GPS
Dunder M5 38626	NW 4 5E 4 Sec 35 Twn 271 Rng 4 100
Dundle, M5 38626 City State Zip Code	
Telephone No. (662)624-4335	Distance Direction Nearest Town  Miles 5 W of Ochon 6
Well I	Data
Purpose of Well (circle one) Home Industrial Public Supply	(Irrigation Fish Culture Other:
Date well drilling started: 2/15/06 Date	well drilling completed: 2/20/06
If flowing, method of flow regulation: Valve Other (d	
Static Water Level:feet above or below (circle one)	land surface Date measured: 2/20/06
Method of Measurement (circle one) steel tape electric tape	air line other:
Hole depth: Well depth:	Well grouted to a depth offeet
Type of grout (circle one): Cement Bentonite Mix	
Casing length: 60 feet Casing diameter: 8	_inches Type of casing: $PVC$
Screen length: 40 feet Screen diameter: 8	inches Type of screen: PVC
Screen slot size: OHO inches Setting depth: From	60 feet to 100 feet
Type of completion (circle all applicable): Gravel packed Under	rreamed Telescoped Open hole Natural Development
Other (describe):	
Top of lap pipe or reduction in casing:feet. If to	elescoped or more than one screen, describe on back of page
Logs run (circle all applicable): No log run Electric Gamma Ray	Density Sonic Neutron Other:
Name of organization running log(s):  I certify that the well was drilled, constructed, and completed in	according to with all applicable provides were of the Minds of
Department of Environmental Quality and/or the Mississippi De	
Pete Sappington 04.	30 Sete Japangton
Print Name of Water Well Contractor and License No.	Signature of Water Well Contractor

RECEIVED

MAR 2 0 2006

BY: OLWR

## STATE WELL REPORT

Date completed:  $\frac{2/20/06}{}$ 

Part 2 Pump Installer's Completion Report Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 10631

Jackson, MS 39289-0631 (601)961-5210 (601)354-6938 (fax)

For Office Use Only:
Aquifer:
Well#: <b>B</b> - 47
Elevation:

This report should be prepared by the pump installer in deta installation of pump.	il and filed with the Department within 30 days of the
Well Owner Information	Well Location
Owner Name: Rodney Larrison	Latitude:Longitude:
Mailing Address: 5030 moon Lake Rd.	Method of Lat/Long (circle one): Conventional Survey,
	USGS quad, Hand-held GPS, Survey-grade GPS
Dunolu, MS 38626 City State Zip Code	NW 4 SE 4 Sec 35 Twn 29N Rng 4 W
	Distance Direction Nearest Town
Telephone No. (662) 624-4335	4 Miles 5W of Cashoma
Pump Type Circle one	Power Type Circle one
Air Lift Jet Submersible	Diesel Engine Gasoline Engine Natural Gas
Bucket Piston Turbine	Electric Motor Hand Tractor PTO
Centrifugal Rotary Flowing Well	Windmill Other (specify):
Other (specify);	Horse Power Rating of Motor: 15 hp
Date Pump Installed: 2/20/06	Setting Depth:feet
Rated Pump Capacity: 1000 Gallons Per Minute	Number of Stages:/
Pump Test Data	Method of Measuring Water Level
Date Well Tested: 2/20/06	Circle one
Static Water Level (A): /8 Feet Below Land Surface	Air Line Electric Measuring Line Steel Tape
Pumping Water Level (B): 45 Feet Below Land Surface	Other (specify):
Drawdown [(B) - (A)]: 27 Feet Below Land Surface	For flowing well, measured shut in head:feet
Test Pumping Rate: 1000 Gallons Per Minute	Well yieldedGPM with a drawdown of
Duration of Pump Test (minimum 4 hours):hours	feet afterhours of pumping
I HEREBY CERTIFY that the above statements are true to the best	

Pete Sappington 0430
Print Name of Pump Installer and License No. (if applicable)

Signature of Pump Installer

RECEIVED

MAR 2 0 2006

BY: OLWR

If more than one screen, show location of each on sketch

aid in locating the well; 3) any roads, power lit 4) indicate direction.	Black Top	
Seit 35	•	
	Dix Pd	
ndowner Name:	***	

RECEIVED
MAR 2 0 2006

BY: OLWR