MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES

Bureau of Land and Water Resources

P.O. Box 10631
Jackson, Mississippi 39209

WATER WELL DRILLERS LOG

CODED

COUNTY WELL LOCATED	Coahoma
WELL NUMBER	F 56
CODED	
PERMIT NUMBER	7109
NAME OF DRILLING FIRM	Irrigation Equipment Indianola, MS
DATE WELL COMPLETED	3-6-87

NAME & MAILING ADDRESS OF LANDOWNER

Harry Malatesta
1310 West 2nd St.
Clarksdale, MS 38614

WELL LOCATION: SEC 18 TOWNSHIP 28 (N) (S) RANGE 3 E (W)

DISTANCE 6 Miles DIRECTION North NEAREST TOWN of Clarksdale

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Irrigation

PUMP DATA

PUMP TYPE (Circle One): Submersible, (Turbine), Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One): Electric, Tractor, (Diesel), Gasoline, Butane, Other (Describe)

Pump Capacity (GPM)	No. of Stages	Setting Depth
2000	1	50 FT.

PUMP TEST

Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
111	16	71

Type of Casing	Hole Depth	Depth to Static Water Level
steel	111	21'

TYPE OF COMPLETION: (Circle One or More): (Gravel Packed), Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

Top of Lap Pipe or Reduction in Casing FEET

IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

CODED

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks
#7109

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
16	40	.060

Screen Type	Depth to Bottom - Feet
Steel	40

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Sandy Loam	0	15
Fine sand with clay	15	25
Clay	25	55
Fine sand	55	70
Coarse sand with gravel	70	111

FORMATIONS (Continued)	FROM	TO

RECEIVED
MAR 23 1987
Department of Natural Resources
Bureau of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK