

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES

Bureau of Land and Water Resources

Coahoma  
ATFD  
NUMBER  
A 2003  
CODED

PERMIT NUMBER

NAME OF DRILLING FIRM

Howell Construction  
Clarksdale MS

P.O. Box 10631

Jackson, Mississippi 39209

WATER WELL DRILLERS LOG

DATE WELL COMPLETED  
6-14-90

NAME & MAILING ADDRESS OF LANDOWNER

Alvin Dugard  
715 West Second  
Clarksdale MS 38614

PUMP DATA

PUMP TYPE (Circle One):  
Submersible, Turbine, Jet, Flowing Well,  
Other (Describe)

POWER TYPE (Circle One):  
Electric, Tractor, Diesel, Gasoline, Butane,  
Other (Describe) H/P

Pump Capacity (GPM) No. of Stages Setting Depth  
2000-2500 2 60 FT.

PUMP TEST

Well yielded \_\_\_\_\_ GPM with  
a drawdown of \_\_\_\_\_ ft.  
after \_\_\_\_\_ hours of pumping

WELL LOCATION: SEC TOWNSHIP RANGE

15 26 N 5 W

DISTANCE DIRECTION NEAREST TOWN

2 Miles W of Bobo

OTHER LANDMARK

WELL PURPOSE: Home Irrigation Municipal, Industrial, Fish Pond, etc.

WELL DATA

Well Depth Casing Diameter (In.) Casing Length (Ft.)  
100 16 60

Type of Casing Hole Depth Depth to Static Water Level  
steel 100 12'

TYPE OF COMPLETION: (Circle One or More):  
Gravel Packed, Underreamed, Telescoped,  
Natural Development, Open Hole, Other  
(Describe)

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

SCREEN DATA

Diameter - Inches Length - Feet Slot Size - Inches  
16 40 .040

Screen Type Depth to Bottom - Feet  
steel 100

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run,  
Electric, Gamma Ray, Density, Sonic, Neutron,  
Other (Describe)

Name of Organization Running Log

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
<u>Top soil</u>	<u>0</u>	<u>10</u>			
<u>Coarse sand</u>	<u>10</u>	<u>80</u>			
<u>Heavy gravel</u>	<u>80</u>	<u>100</u>			

RECEIVED

OCT 05 1990

Department of Natural Resources  
Bureau of Land & Water Resources

IF MORE SPACE IS NEEDED, USE BACK